

ОТЧЕТ
 О СУТОЧНЫХ ПАРАМЕТРАХ УЗЛА ТЕПЛОСНАБЖЕНИЯ
 Диапазон архива : 23.01.20 - 23.12.19
 Абонент _____ Договор N _____
 Адрес _____
 Теплосчетчик СТУ-1 №. 0 V 2.043
 Схема подключения : 14

Дата/Время	V3, м3	V4, м3	V6, м3	V3-V4	T3, оС	T4, оС	P3, МПа	P4, МПа	M3, Т	M4, Т	M6, Т	E2, ГДж	ТНС, МИН
23.01.20	НетДанных												
22.01.20	62.122	32.407	0.0000	29.715	061.0	044.6	0.700	0.500	61.066	32.101	0.0000	9.5685	0.0000
21.01.20	61.662	31.507	0.0000	30.155	061.4	044.6	0.700	0.500	60.601	31.209	0.0000	9.6898	0.0000
20.01.20	62.466	32.118	0.0000	30.348	061.7	044.3	0.700	0.500	61.383	31.818	0.0000	9.9334	0.0000
19.01.20	66.655	30.754	0.0000	35.901	061.2	044.2	0.700	0.500	65.516	30.469	0.0000	11.051	0.0000
18.01.20	67.483	30.746	0.0000	36.737	061.1	044.2	0.700	0.500	66.333	30.460	0.0000	11.254	0.0000
17.01.20	60.768	30.932	0.0000	29.836	060.8	043.5	0.700	0.500	59.740	30.652	0.0000	9.5404	0.0000
16.01.20	60.532	31.014	0.0000	29.518	062.2	043.9	0.700	0.500	59.467	30.729	0.0000	9.7353	0.0000
15.01.20	61.688	30.871	0.0000	30.817	061.4	043.6	0.700	0.500	60.629	30.591	0.0000	9.9225	0.0000
14.01.20	60.326	29.883	0.0000	30.443	061.6	044.5	0.700	0.500	59.282	29.602	0.0000	9.7156	0.0000
13.01.20	60.894	31.601	0.0000	29.293	060.7	044.0	0.700	0.500	59.870	31.310	0.0000	9.3699	0.0000
12.01.20	71.574	33.746	0.0000	37.828	061.8	044.7	0.700	0.500	70.327	33.426	0.0000	11.857	0.0000
11.01.20	70.184	34.158	0.0000	36.026	061.3	044.5	0.700	0.500	68.979	33.836	0.0000	11.298	0.0000
10.01.20	63.341	34.436	0.0000	28.905	060.1	043.3	0.700	0.500	62.295	34.128	0.0000	9.4381	0.0000
09.01.20	62.705	34.439	0.0000	28.266	061.6	043.7	0.700	0.500	61.618	34.126	0.0000	9.6099	0.0000
08.01.20	65.537	34.389	0.0000	31.148	061.5	044.2	0.700	0.500	64.405	34.070	0.0000	10.223	0.0000
07.01.20	63.105	34.451	0.0000	28.654	061.9	044.3	0.700	0.500	62.004	34.129	0.0000	9.6530	0.0000
06.01.20	64.938	34.356	0.0000	30.582	061.6	044.4	0.700	0.500	63.814	34.035	0.0000	10.079	0.0000
05.01.20	65.849	34.408	0.0000	31.441	061.9	044.5	0.700	0.500	64.700	34.084	0.0000	10.355	0.0000
04.01.20	63.348	34.490	0.0000	28.858	062.1	044.4	0.700	0.500	62.235	34.167	0.0000	9.7801	0.0000
03.01.20	62.208	34.523	0.0000	27.685	062.2	044.3	0.700	0.500	61.114	34.201	0.0000	9.4998	0.0000
02.01.20	63.486	34.551	0.0000	28.936	058.5	042.5	0.700	0.500	62.490	34.254	0.0000	9.1095	0.0000
01.01.20	59.075	34.740	0.0000	24.335	059.5	043.1	0.700	0.500	58.118	34.433	0.0000	8.2288	0.0000
31.12.19	78.654	33.919	0.0000	44.734	058.6	043.3	0.700	0.500	77.414	33.616	0.0000	12.825	0.0000
30.12.19	70.113	35.107	0.0000	35.005	058.9	043.2	0.700	0.500	68.997	34.795	0.0000	10.676	0.0000
29.12.19	72.505	35.757	0.0000	36.748	058.7	043.5	0.700	0.500	71.359	35.434	0.0000	11.056	0.0000
28.12.19	69.728	35.968	0.0000	33.760	059.0	043.5	0.700	0.500	68.616	35.644	0.0000	10.406	0.0000
27.12.19	65.223	36.203	0.0000	29.020	059.0	043.5	0.700	0.500	64.183	35.877	0.0000	9.3055	0.0000
26.12.19	66.089	36.200	0.0000	29.888	059.2	043.6	0.700	0.500	65.027	35.873	0.0000	9.5196	0.0000
25.12.19	66.790	36.220	0.0000	30.570	059.3	043.8	0.700	0.500	65.715	35.889	0.0000	9.6852	0.0000
24.12.19	66.200	36.201	0.0000	29.999	059.1	043.5	0.700	0.500	65.130	35.899	0.0000	9.5019	0.0000
ИТОГО:	1955.2	1010.1	0.0000	945.15	058.6	042.5	0.700	0.500	1923.3	1000.9	0.0000	301.88	0.0000

Подпись
 "56"

Handwritten signature

ОТЧЕТ
о суточных параметрах узла теплоснабжения
диапазон архива : 23.01.20 - 23.12.19
Абонент _____ Договор N _____

Адрес _____
Теплосчетчик СТУ-1 NO. 0 V 2.043
Схема подключения : 14

Дата/время	V1, м3 Нетданных	V2, м3	V5, м3	V1-V2	T1, оС	T2, оС	P1, мПа	P2, мПа	M1, Т	M2, Т	M5, Т	E1, ГДЖ	ТНС, МИН
23.01.20	1629.3	1608.3	0.0000	21.002	052.5	049.1	0.700	0.500	1608.4	1590.0	0.0000	23.647	0.0000
22.01.20	1649.3	1624.4	0.0000	24.976	054.2	050.4	0.700	0.500	1626.9	1604.9	0.0000	25.919	0.0000
21.01.20	1725.8	1698.7	0.0000	27.130	055.0	051.2	0.700	0.500	1701.7	1677.8	0.0000	27.232	0.0000
20.01.20	1726.4	1699.1	0.0000	27.354	054.5	050.8	0.700	0.500	1702.6	1678.5	0.0000	27.072	0.0000
19.01.20	1729.4	1702.0	0.0000	27.378	052.5	049.0	0.700	0.500	1707.2	1682.7	0.0000	25.139	0.0000
18.01.20	1724.1	1696.5	0.0000	27.617	051.4	048.1	0.700	0.500	1702.9	1678.0	0.0000	24.049	0.0000
17.01.20	1712.5	1684.1	0.0000	28.365	053.6	049.9	0.700	0.500	1689.7	1664.3	0.0000	26.208	0.0000
16.01.20	1725.3	1696.0	0.0000	29.258	057.6	053.3	0.700	0.500	1698.9	1673.5	0.0000	30.881	0.0000
15.01.20	1727.3	1698.8	0.0000	28.463	054.9	051.1	0.700	0.500	1703.2	1678.0	0.0000	28.166	0.0000
14.01.20	1657.6	1629.3	0.0000	28.339	055.5	051.4	0.700	0.500	1634.0	1609.1	0.0000	34.854	0.0000
13.01.20	1703.8	1674.2	0.0000	29.642	061.2	056.3	0.700	0.500	1674.6	1649.5	0.0000	29.343	0.0000
12.01.20	1510.9	1484.1	0.0000	26.734	058.3	053.9	0.700	0.500	1487.3	1464.0	0.0000	30.303	0.0000
11.01.20	1707.2	1678.8	0.0000	28.465	056.2	052.0	0.700	0.500	1682.3	1657.5	0.0000	28.457	0.0000
10.01.20	1711.8	1683.6	0.0000	28.159	054.3	050.3	0.700	0.500	1688.4	1663.5	0.0000	25.601	0.0000
09.01.20	1713.3	1686.2	0.0000	27.066	051.7	048.1	0.700	0.500	1692.0	1667.8	0.0000	22.631	0.0000
08.01.20	1713.2	1686.8	0.0000	26.376	049.0	045.8	0.700	0.500	1694.0	1670.0	0.0000	22.768	0.0000
07.01.20	1713.2	1686.8	0.0000	27.373	049.4	046.2	0.700	0.500	1693.6	1668.9	0.0000	23.100	0.0000
06.01.20	1713.3	1686.0	0.0000	26.656	049.7	046.5	0.700	0.500	1693.3	1669.4	0.0000	23.433	0.0000
05.01.20	1713.4	1686.8	0.0000	26.508	049.8	046.6	0.700	0.500	1693.0	1669.5	0.0000	23.993	0.0000
04.01.20	1713.2	1686.7	0.0000	26.508	049.8	046.9	0.700	0.500	1693.0	1669.5	0.0000	24.220	0.0000
03.01.20	1713.2	1687.1	0.0000	26.171	050.2	046.9	0.700	0.500	1690.3	1667.3	0.0000	27.740	0.0000
02.01.20	1710.9	1685.3	0.0000	25.637	050.8	047.5	0.700	0.500	1686.4	1664.2	0.0000	28.635	0.0000
01.01.20	1710.1	1684.7	0.0000	25.362	054.8	050.9	0.700	0.500	1686.9	1664.9	0.0000	28.423	0.0000
31.12.19	1711.0	1685.7	0.0000	25.365	055.3	051.3	0.700	0.500	1684.6	1662.0	0.0000	31.319	0.0000
30.12.19	1708.5	1682.5	0.0000	25.985	054.9	050.9	0.700	0.500	1688.2	1664.0	0.0000	30.429	0.0000
29.12.19	1714.4	1686.4	0.0000	28.008	057.6	053.3	0.700	0.500	1686.8	1662.2	0.0000	30.589	0.0000
28.12.19	1712.5	1684.2	0.0000	27.705	057.1	052.8	0.700	0.500	1684.6	1660.6	0.0000	30.950	0.0000
27.12.19	1710.6	1682.9	0.0000	27.705	057.5	053.2	0.700	0.500	1684.5	1660.6	0.0000	31.228	0.0000
26.12.19	1711.0	1683.2	0.0000	27.705	058.0	053.6	0.700	0.500	1683.4	1659.6	0.0000	31.068	0.0000
25.12.19	1710.2	1682.6	0.0000	27.658	058.4	054.0	0.700	0.500	1687.3	1661.3	0.0000	825.28	0.0000
24.12.19	1714.1	1684.2	0.0000	29.865	058.3	054.0	0.700	0.500	050344	049652	0.0000		
	ИТОГО:	051020	0.0000	784.77	052.5	048.8	0.677	0.483					

196, 96 Nov

Подпись _____
"97"

варейкиса 36 отопление февраль 20.txt

ОТЧЕТ

о Суточных параметрах узла теплоснабжения
 Диапазон архива : 25.02.20 - 23.01.20

Абонент _____ Договор N _____

Адрес _____
 Теллосчетчик СТУ-1 No. 0 V 2.043

Схема подключения : 14

Дата/Время	V1,м3	V2,м3	V5,м3	V1-V2	T1,оС	T2,оС	P1,МПа	P2,МПа	M1,Т	M2,Т	M5,Т
Е1,ГДЖ	тНС,МИН										
25.02.20	НетДанных										
24.02.20	1705.4	1679.2	0.0000	26.206	052.6	049.2	0.700	0.500	1683.5	1660.1	0.0000
24.327	0.0000										
23.02.20	1700.9	1674.2	0.0000	26.700	055.7	051.8	0.700	0.500	1676.5	1653.1	0.0000
27.678	0.0000										
22.02.20	1702.5	1675.9	0.0000	26.573	055.0	051.2	0.700	0.500	1678.6	1655.3	0.0000
26.971	0.0000										
21.02.20	1703.1	1676.8	0.0000	26.317	053.9	050.2	0.700	0.500	1680.1	1656.8	0.0000
26.292	0.0000										
20.02.20	1707.2	1682.1	0.0000	25.158	050.6	047.4	0.700	0.500	1686.8	1664.2	0.0000
23.034	0.0000										
19.02.20	1703.6	1678.1	0.0000	25.561	051.6	048.2	0.700	0.500	1682.5	1659.6	0.0000
24.249	0.0000										
18.02.20	1697.0	1671.3	0.0000	25.618	051.1	047.6	0.700	0.500	1676.3	1653.4	0.0000
24.361	0.0000										
17.02.20	1501.1	1478.3	0.0000	22.806	050.3	046.8	0.700	0.500	1483.4	1463.0	0.0000
21.678	0.0000										
16.02.20	1481.1	1454.4	0.0000	26.689	057.8	052.9	0.700	0.500	1458.4	1435.3	0.0000
29.760	0.0000										
15.02.20	1481.5	1454.8	0.0000	26.736	058.2	053.3	0.700	0.500	1458.5	1435.5	0.0000
30.308	0.0000										
14.02.20	1481.1	1453.2	0.0000	27.866	063.0	057.3	0.700	0.500	1454.4	1431.2	0.0000
35.341	0.0000										
13.02.20	1480.8	1453.9	0.0000	26.868	061.7	056.1	0.700	0.500	1455.1	1432.7	0.0000
34.321	0.0000										
12.02.20	1481.3	1455.2	0.0000	26.123	057.7	052.8	0.700	0.500	1458.7	1436.2	0.0000
29.989	0.0000										
11.02.20	1299.2	1275.5	0.0000	23.720	057.3	051.9	0.700	0.500	1279.6	1259.4	0.0000
27.848	0.0000										
10.02.20	1607.9	1577.7	0.0000	30.255	062.4	057.2	0.700	0.500	1579.5	1553.8	0.0000
34.385	0.0000										
09.02.20	1702.9	1668.9	0.0000	34.013	068.4	062.5	0.700	0.500	1667.1	1639.1	0.0000
41.790	0.0000										
08.02.20	1701.4	1668.0	0.0000	33.388	067.1	061.4	0.700	0.500	1666.9	1639.2	0.0000
40.198	0.0000										
07.02.20	1704.0	1672.0	0.0000	31.970	062.8	057.8	0.700	0.500	1673.4	1646.1	0.0000
35.057	0.0000										

варейкиса 36 отопление февраль 20.txt																							
06.02.20		1704.4		1672.8		0.0000		31.623		062.6		057.6*		0.700		0.500		1674.0		1647.0		0.0000	
35.068		0.0000		1679.5		0.0000		30.083		058.9		054.5		0.700		0.500		1682.3		1656.2		0.0000	
05.02.20		1709.6		1637.3		0.0000		28.646		051.9		048.5		0.700		0.500		1645.0		1619.1		0.0000	
31.584		0.0000		1674.4		0.0000		29.142		050.4		047.2		0.700		0.500		1683.3		1656.7		0.0000	
04.02.20		1665.9		1674.3		0.0000		29.573		051.0		047.7		0.700		0.500		1683.2		1656.2		0.0000	
24.297		0.0000		1672.7		0.0000		29.553		051.1		047.7		0.700		0.500		1681.6		1654.7		0.0000	
03.02.20		1703.5		1672.7		0.0000		29.511		051.8		048.4		0.700		0.500		1681.0		1654.2		0.0000	
22.875		0.0000		1675.1		0.0000		29.847		054.4		050.7*		0.700		0.500		1681.5		1654.8		0.0000	
02.02.20		1703.8		1679.4		0.0000		31.333		062.5		057.6		0.700		0.500		1680.3		1653.6		0.0000	
23.517		0.0000		1677.7		0.0000		33.479		067.0		061.3		0.700		0.500		1674.6		1646.8		0.0000	
01.02.20		1702.3		1681.0		0.0000		31.438		059.7		055.1		0.700		0.500		1681.3		1654.0		0.0000	
31.01.20		1702.2		1683.3		0.0000		30.995		059.0		054.6		0.700		0.500		1684.7		1657.7		0.0000	
24.397		0.0000		1683.3		0.0000		29.791		056.6		052.6		0.700		0.500		1687.8		1661.5		0.0000	
30.01.20		1704.9		1673.6		0.0000		32.977		063.2		058.1		0.700		0.500		1675.7		1647.5		0.0000	
26.490		1.0000		051779		0.0000		920.54		055.7		051.4*		0.679		0.485		051896		051094		0.0000	
29.01.20		1710.7																					
35.167		0.0000																					
28.01.20		1709.1																					
40.411		0.0000																					
27.01.20		1709.2																					
32.189		0.0000																					
26.01.20		1712.0																					
31.339		0.0000																					
25.01.20		1713.1																					
28.426		0.0000																					
24.01.20		1706.6																					
35.800		0.0000																					
ИТОГО:		052700																					
952.76		1.0000																					

Подпись
"ЕВ"

ГЧЕТ
 СУТОЧНЫХ параметрах Узла теплоснабжения
 ипазона архива : 25.02.20 - 23.01.20
 Бонент _____ Договор N _____
 дрес _____
 еплосчетчик СТУ-1 No. 0 V 2.043
 хема подключения : 14

ата/Время	V3, м3	V4, м3	V6, м3	V3-V4	T3, оС	T4, оС	P3, МПа	P4, МПа	M3, Т	M4, Т	M6, Т	E2, ГДж	тНС, МИН
5.02.20	НетДанных			35.260	061.5	043.0	0.700	0.500	60.043	25.609	0.0000	10.775	0.0000
4.02.20	61.097	25.837	0.0000	29.709	061.8	042.8	0.700	0.500	54.850	25.885	0.0000	9.5266	0.0000
3.02.20	55.822	26.113	0.0000	30.762	061.9	042.9	0.700	0.500	55.817	25.818	0.0000	9.7695	0.0000
2.02.20	56.809	26.047	0.0000	28.852	062.0	042.9	0.700	0.500	54.031	25.912	0.0000	9.3283	0.0000
1.02.20	54.994	26.142	0.0000	30.465	061.8	042.7	0.700	0.500	55.648	25.940	0.0000	9.7417	0.0000
0.02.20	56.633	26.167	0.0000	32.567	061.4	042.6	0.700	0.500	57.636	25.851	0.0000	10.146	0.0000
9.02.20	58.643	26.076	0.0000	28.823	061.7	042.3	0.700	0.500	54.114	26.023	0.0000	9.3174	0.0000
8.02.20	55.070	26.247	0.0000	29.964	060.9	041.9	0.700	0.500	54.783	25.548	0.0000	9.4326	0.0000
7.02.20	55.728	25.764	0.0000	38.589	061.9	043.0	0.700	0.500	62.839	25.144	0.0000	11.695	0.0000
6.02.20	63.956	25.367	0.0000	32.023	062.4	043.1	0.700	0.500	56.695	25.467	0.0000	10.176	0.0000
5.02.20	57.717	25.694	0.0000	32.009	063.3	043.8	0.700	0.500	56.838	25.647	0.0000	10.350	0.0000
4.02.20	57.892	25.883	0.0000	30.063	063.3	043.7	0.700	0.500	54.903	25.620	0.0000	9.8556	0.0000
3.02.20	55.919	25.856	0.0000	31.565	061.7	042.7	0.700	0.500	56.486	25.694	0.0000	9.9267	0.0000
2.02.20	57.484	25.919	0.0000	30.743	061.8	042.6	0.700	0.500	55.465	25.483	0.0000	9.7866	0.0000
1.02.20	56.449	25.705	0.0000	30.142	062.6	043.8	0.700	0.500	56.214	26.846	0.0000	9.7290	0.0000
0.02.20	57.235	27.093	0.0000	35.844	063.6	044.7	0.700	0.500	62.059	27.114	0.0000	11.366	0.0000
9.02.20	63.219	27.375	0.0000	34.006	063.5	044.8	0.700	0.500	60.319	27.177	0.0000	10.918	0.0000
8.02.20	61.444	27.439	0.0000	30.005	062.5	044.1	0.700	0.500	56.483	27.245	0.0000	9.6998	0.0000
7.02.20	57.504	27.499	0.0000	30.874	062.0*	044.1*	0.700	0.500	57.867	27.767	0.0000	9.8596	0.0000
6.02.20	58.900	28.026	0.0000	30.031	061.9	044.2	0.700	0.500	58.696	29.431	0.0000	9.7244	0.0000
5.02.20	59.739	29.707	0.0000	33.466	060.8	043.7	0.700	0.500	61.949	29.280	0.0000	10.327	0.0000
4.02.20	63.014	29.548	0.0000	29.803	060.2	043.3	0.700	0.500	58.489	29.409	0.0000	9.3242	0.0000
3.02.20	59.476	29.674	0.0000	40.069	059.7	043.2	0.700	0.500	68.258	29.059	0.0000	11.639	0.0000
2.02.20	69.389	29.320	0.0000	33.671	060.5	043.6	0.700	0.500	62.129	29.248	0.0000	10.319	0.0000
1.02.20	63.186	29.515	0.0000	32.816	060.5	043.8	0.700	0.500	61.507	29.467	0.0000	10.124	0.0000
0.01.20	62.555	29.739	0.0000	30.520	060.6*	043.8*	0.700	0.500	59.891	30.117	0.0000	9.5776	1.0000
0.01.20	60.914	30.394	0.0000	30.964	062.2	044.9	0.700	0.500	61.579	31.415	0.0000	10.061	0.0000
9.01.20	62.683	31.719	0.0000	30.758	062.5	045.3	0.700	0.500	61.610	31.656	0.0000	10.080	0.0000
8.01.20	62.726	31.968	0.0000	28.005	061.7	044.8	0.700	0.500	59.079	31.811	0.0000	9.2473	0.0000
7.01.20	60.122	32.117	0.0000	36.867	061.1	044.7	0.700	0.500	67.736	31.741	0.0000	11.279	0.0000
6.01.20	68.912	32.045	0.0000	32.027	061.4	044.9	0.700	0.500	63.210	31.981	0.0000	10.210	0.0000
5.01.20	64.317	32.290	0.0000	30.121	061.6	045.0	0.700	0.500	61.467	32.115	0.0000	9.7576	0.0000
4.01.20	62.548	32.427	0.0000	1021.4	059.9*	042.3*	0.679	0.485	1888.7	892.52	0.0000	323.07	1.0000
ИТОГО:	1922.1	900.71	0.0000										

Подпись
 "Е8"

ОТЧЕТ

о суточных параметрах узла теплоснабжения
 Диапазон архива : 24.03.20 - 24.02.20

Абонент _____ Договор N _____

Адрес _____
 Теплосчетчик СТУ-1 No. 0 V 2.043

Схема подключения : 14

Дата/Время	V1, м3	V2, м3	V5, м3	V1-V2	T1, оС	T2, оС	P1, мпа	P2, мпа	M1, т	M2, т	M5, т	E1, ГДЖ	ТНС, мин
24.03.20	нетДанных	1664.7	0.0000	28.639	054.9	051.1	0.700	0.500	1669.7	1644.3	0.0000	27.106	0.0000
23.03.20	1693.4	1668.1	0.0000	28.732	054.6	050.9	0.700	0.500	1673.5	1647.8	0.0000	26.309	0.0000
22.03.20	1696.9	1673.8	0.0000	28.003	052.1	048.8	0.700	0.500	1680.4	1655.0	0.0000	23.590	0.0000
21.03.20	1701.8	1678.8	0.0000	27.245	050.0	046.9	0.700	0.500	1686.2	1661.3	0.0000	21.778	0.0000
20.03.20	1706.1	1678.8	0.0000	26.972	045.5	043.1	0.700	0.500	1696.5	1671.3	0.0000	17.445	0.0000
19.03.20	1713.2	1686.3	0.0000	26.976	047.0	044.4	0.700	0.500	1692.2	1667.2	0.0000	18.853	0.0000
18.03.20	1709.9	1682.9	0.0000	27.320	050.0	046.9	0.700	0.500	1685.3	1660.3	0.0000	21.589	0.0000
17.03.20	1705.1	1677.8	0.0000	27.315	052.7	049.3	0.700	0.500	1677.5	1652.9	0.0000	24.205	0.0000
16.03.20	1699.4	1672.1	0.0000	26.875	051.6	048.4	0.700	0.500	1682.6	1658.3	0.0000	23.016	0.0000
15.03.20	1703.7	1676.8	0.0000	26.625	048.0	045.2	0.700	0.500	1691.4	1666.8	0.0000	19.895	0.0000
14.03.20	1709.8	1683.2	0.0000	26.348	045.5	043.1	0.700	0.500	1695.5	1670.9	0.0000	17.481	0.0000
13.03.20	1712.2	1685.8	0.0000	25.952	044.9	042.5	0.700	0.500	1696.6	1672.3	0.0000	17.122	0.0000
12.03.20	1712.8	1686.9	0.0000	25.384	043.5	041.4	0.700	0.500	1699.0	1675.1	0.0000	15.496	0.0000
11.03.20	1714.3	1688.9	0.0000	25.546	047.8	045.0	0.700	0.500	1689.8	1666.3	0.0000	19.556	0.0000
10.03.20	1708.0	1682.5	0.0000	26.063	047.3	044.6	0.700	0.500	1694.1	1670.1	0.0000	19.323	0.0000
09.03.20	1712.1	1686.0	0.0000	26.137	048.0	045.3	0.700	0.500	1692.9	1668.9	0.0000	20.086	0.0000
08.03.20	1711.4	1685.3	0.0000	26.111	050.7	047.5	0.700	0.500	1685.8	1662.2	0.0000	22.679	0.0000
07.03.20	1706.2	1680.1	0.0000	26.391	052.0	048.7	0.700	0.500	1679.7	1656.0	0.0000	23.964	0.0000
06.03.20	1701.1	1674.7	0.0000	24.755	052.0	048.7	0.700	0.500	1546.9	1524.4	0.0000	21.932	0.0000
05.03.20	1565.5	1540.7	0.0000	26.033	050.5	047.3	0.700	0.500	1680.6	1657.2	0.0000	23.772	0.0000
04.03.20	1701.9	1675.8	0.0000	25.751	049.8	048.5	0.700	0.500	1685.1	1661.7	0.0000	21.999	0.0000
03.03.20	1704.9	1679.1	0.0000	25.943	049.9	046.8	0.700	0.500	1686.8	1663.2	0.0000	21.797	0.0000
02.03.20	1706.4	1680.5	0.0000	25.667	049.6	046.6	0.700	0.500	1614.9	1592.0	0.0000	24.769	0.0000
01.03.20	1636.5	1610.9	0.0000	25.667	053.5	049.9	0.700	0.500	1679.0	1655.7	0.0000	24.824	0.0000
29.02.20	1701.1	1675.0	0.0000	26.111	052.9	049.4	0.700	0.500	1689.3	1666.1	0.0000	20.577	0.0000
28.02.20	1708.0	1682.7	0.0000	25.288	048.4	045.5	0.700	0.500	1689.3	1662.9	0.0000	22.122	0.0000
27.02.20	1706.2	1680.7	0.0000	25.535	050.4	047.3	0.700	0.500	1686.0	1662.9	0.0000	26.400	0.0000
26.02.20	1699.7	1673.5	0.0000	26.153	054.9	051.2	0.700	0.500	1676.0	1653.0	0.0000	26.400	0.0000
25.02.20	1701.7	1675.4	0.0000	26.240	053.8	050.2	0.700	0.500	1678.8	1655.5	0.0000	25.592	0.0000
ИТОГО:	047560	046820	0.0000	739.73	048.5	045.5	0.677	0.483	046992	046313	0.0000	613.27	0.0000

ПОДПИСЬ
 "69"

ных параметрах узла теплоснабжения
он архива : 24.03.20 - 24.02.20
нт _____ Договор N _____

С
лосчетчик СТУ-1 No. 0 V 2.043
хема подключения : 14

Дата/Время	V3, м3	V4, м3	V6, м3	V3-V4	T3, оС	T4, оС	P3, МПа	P4, МПа	M3, т	M4, т	M6, т	E2, ГДж	ТНС, мин
24.03.20	Нет данных												
23.03.20	76.727	44.870	0.0000	31.857	060.2	046.0	0.700	0.500	75.457	44.419	0.0000	10.447	0.0000
22.03.20	79.931	44.676	0.0000	35.255	060.0	046.1	0.700	0.500	78.613	44.227	0.0000	11.139	0.0000
21.03.20	78.826	44.785	0.0000	34.041	059.9	046.1	0.700	0.500	77.531	44.332	0.0000	10.809	0.0000
20.03.20	75.587	44.933	0.0000	30.653	059.9	046.2	0.700	0.500	74.345	44.479	0.0000	9.9918	0.0000
19.03.20	76.373	44.838	0.0000	31.535	059.5	045.8	0.700	0.500	75.135	44.392	0.0000	10.143	0.0000
18.03.20	75.121	44.940	0.0000	30.181	059.6	045.8	0.700	0.500	73.901	44.494	0.0000	9.8257	0.0000
17.03.20	73.641	43.479	0.0000	30.162	059.9	045.7	0.700	0.500	72.433	43.048	0.0000	9.8046	0.0000
16.03.20	75.747	44.988	0.0000	30.759	060.2	046.4	0.700	0.500	74.490	44.529	0.0000	10.084	0.0000
15.03.20	80.790	44.605	0.0000	36.185	059.7	046.4	0.700	0.500	79.472	44.150	0.0000	11.186	0.0000
14.03.20	77.517	44.718	0.0000	32.799	059.6	046.2	0.700	0.500	76.254	44.265	0.0000	10.416	0.0000
13.03.20	75.606	44.670	0.0000	30.937	059.7	046.1	0.700	0.500	74.373	44.219	0.0000	9.9709	0.0000
12.03.20	64.572	34.014	0.0000	30.558	056.7	042.8	0.700	0.500	63.616	33.716	0.0000	9.2076	0.0000
11.03.20	73.769	43.551	0.0000	30.218	059.3	045.0	0.700	0.500	72.579	43.131	0.0000	9.7998	0.0000
10.03.20	73.300	43.659	0.0000	29.642	059.9	045.4	0.700	0.500	72.098	43.232	0.0000	9.7872	0.0000
09.03.20	80.188	43.296	0.0000	36.892	059.4	045.4	0.700	0.500	78.890	42.872	0.0000	11.346	0.0000
08.03.20	74.605	43.663	0.0000	30.942	059.6	045.2	0.700	0.500	73.389	43.240	0.0000	10.074	0.0000
07.03.20	76.085	43.568	0.0000	32.518	059.8	045.2	0.700	0.500	74.840	43.145	0.0000	10.514	0.0000
06.03.20	66.951	39.129	0.0000	27.821	060.1	044.2	0.700	0.500	65.845	38.766	0.0000	9.2798	0.0000
05.03.20	54.031	24.132	0.0000	29.899	059.2	041.4	0.700	0.500	53.163	23.934	0.0000	8.9724	0.0000
04.03.20	55.939	24.235	0.0000	31.704	059.6	041.2	0.700	0.500	55.029	24.038	0.0000	9.5253	0.0000
03.03.20	53.319	23.995	0.0000	29.324	059.8	043.2	0.700	0.500	52.445	23.782	0.0000	8.8153	0.0000
02.03.20	52.437	23.512	0.0000	28.926	059.2	041.2	0.700	0.500	51.596	23.321	0.0000	8.7791	0.0000
01.03.20	59.452	24.164	0.0000	35.288	059.7	041.5	0.700	0.500	58.481	23.966	0.0000	10.384	0.0000
29.02.20	56.478	24.243	0.0000	32.235	059.8	041.4	0.700	0.500	55.552	24.045	0.0000	9.7309	0.0000
28.02.20	53.237	24.321	0.0000	28.916	059.7	041.1	0.700	0.500	52.367	24.124	0.0000	8.8973	0.0000
27.02.20	55.215	24.292	0.0000	30.923	059.6	041.2	0.700	0.500	54.316	24.095	0.0000	9.3635	0.0000
26.02.20	54.039	24.314	0.0000	29.725	059.7	041.2	0.700	0.500	53.156	24.117	0.0000	9.0816	0.0000
25.02.20	55.559	24.361	0.0000	31.199	060.3	042.2	0.700	0.500	54.636	24.153	0.0000	9.4899	0.0000
ИТОГО:	1905.0	1023.9	0.0000	881.09	057.7	042.6	0.677	0.483	1874.0	1014.2	0.0000	276.96	0.0000

Подпись
"ВО"

ОТЧЕТ

о суточных параметрах узла теплоснабжения
 Диапазон архива : 23.04.20 - 23.03.20
 Абонент _____ Договор N _____

Адрес _____
 Теплосчетчик СТУ-1 No. 0 V 2.043
 Схема подключения : 14

Дата/Время	V1, м3	V2, м3	V5, м3	V1-V2	T1, оС	T2, оС	P1, МПа	P2, МПа	M1, Т	M2, Т	M5, Т	E1, ГДЖ	ТНС, МИН
23.04.20	1696.9	1667.4	0.0000	29.518	046.9	044.2	0.700	0.500	1679.4	1651.9	0.0000	18.651	0.0000
22.04.20	1697.8	1668.5	0.0000	29.304	047.1	044.5	0.700	0.500	1680.1	1652.8	0.0000	18.706	0.0000
21.04.20	1705.3	1676.7	0.0000	28.659	045.1	042.8	0.700	0.500	1689.0	1662.1	0.0000	16.767	0.0000
20.04.20	1712.1	1683.4	0.0000	28.768	043.6	041.4	0.700	0.500	1696.8	1669.5	0.0000	15.378	0.0000
19.04.20	1708.6	1680.6	0.0000	28.044	044.3	042.1	0.700	0.500	1692.9	1666.4	0.0000	16.115	0.0000
18.04.20	1702.2	1673.5	0.0000	28.754	045.9	043.4	0.700	0.500	1685.4	1658.4	0.0000	17.617	0.0000
17.04.20	1701.4	1672.4	0.0000	28.997	046.0	043.5	0.700	0.500	1684.5	1657.3	0.0000	17.535	0.0000
16.04.20	1699.2	1670.3	0.0000	28.841	046.4	043.9	0.700	0.500	1682.0	1655.0	0.0000	18.020	0.0000
15.04.20	1705.9	1677.6	0.0000	28.232	044.3	042.0	0.700	0.500	1690.1	1663.5	0.0000	16.031	0.0000
14.04.20	1707.0	1678.9	0.0000	28.137	043.8	041.6	0.700	0.500	1691.6	1665.0	0.0000	15.385	0.0000
13.04.20	1699.0	1670.1	0.0000	28.901	046.9	044.3	0.700	0.500	1681.5	1654.5	0.0000	18.468	0.0000
12.04.20	1700.3	1671.2	0.0000	29.114	046.9	044.3	0.700	0.500	1682.8	1655.6	0.0000	18.363	0.0000
11.04.20	1705.8	1677.5	0.0000	28.385	043.8	041.6	0.700	0.500	1690.4	1663.6	0.0000	16.415	0.0000
10.04.20	1710.3	1681.6	0.0000	28.708	041.2	039.4	0.700	0.500	1696.6	1669.1	0.0000	12.869	0.0000
09.04.20	1709.8	1681.4	0.0000	28.431	043.1	041.1	0.700	0.500	1694.8	1667.9	0.0000	14.907	0.0000
08.04.20	1705.4	1678.9	0.0000	26.542	044.6	042.3	0.700	0.500	1689.5	1664.6	0.0000	16.552	0.0000
07.04.20	1697.5	1670.4	0.0000	27.029	046.8	044.2	0.700	0.500	1680.0	1654.9	0.0000	18.547	0.0000
06.04.20	1693.9	1666.8	0.0000	27.051	049.7	046.7	0.700	0.500	1674.3	1649.5	0.0000	21.259	0.0000
05.04.20	1704.0	1677.4	0.0000	26.619	043.8	041.6	0.700	0.500	1688.6	1663.5	0.0000	15.757	0.0000
04.04.20	1714.8	1688.1	0.0000	26.715	043.4	041.4	0.700	0.500	1699.5	1674.3	0.0000	14.813	0.0000
03.04.20	1715.1	1688.1	0.0000	27.071	045.0	042.7	0.700	0.500	1698.8	1673.4	0.0000	16.713	0.0000
02.04.20	1707.5	1679.9	0.0000	27.558	048.9	046.1	0.700	0.500	1688.4	1663.0	0.0000	20.112	0.0000

01.04.20	1698.6	1670.5	0.0000	28.098	053.2	049.8	0.700	0.500	1676.3	1651.0	0.0000	24.306	0.0000
31.03.20	1699.8	1672.5	0.0000	27.302	044.0	041.8	0.700	0.500	1684.3	1658.5	0.0000	15.600	0.0000
30.03.20	1702.7	1676.1	0.0000	26.644	043.0	041.0	0.700	0.500	1687.9	1662.7	0.0000	14.476	0.0000
29.03.20	1715.0	1688.1	0.0000	26.911	043.9	041.8	0.700	0.500	1699.5	1674.1	0.0000	15.445	0.0000
28.03.20	1713.6	1686.3	0.0000	27.328	044.9	042.5	0.700	0.500	1697.4	1671.7	0.0000	16.694	0.0000
27.03.20	1713.6	1686.5	0.0000	27.009	044.7	042.4	0.700	0.500	1697.4	1672.1	0.0000	16.568	0.0000
26.03.20	1713.5	1686.1	0.0000	27.404	045.6	043.2	0.700	0.500	1696.7	1671.1	0.0000	17.557	0.0000
25.03.20	1702.1	1673.8	0.0000	28.302	051.2	048.0	0.700	0.500	1681.3	1655.6	0.0000	23.045	0.0000
24.03.20	1694.1	1665.0	0.0000	29.077	054.3	050.6	0.700	0.500	1671.0	1645.0	0.0000	26.114	0.0000
ИТОГО:	052853	051985	0.0000	867.46	045.9	043.4	0.700	0.500	052329	051517	0.0000	544.78	0.0000

Подпись _____
"39"

о суточных параметрах узла теплоснабжения
 Диапазон архива : 23.04.20 - 23.03.20
 Абонент _____ Договор N _____
 Адрес _____
 Теплосчетчик СТУ-1 No. 0 V 2.043
 Схема подключения : 14

Дата/Время	V3, м3	V4, м3	V6, м3	V3-V4	T3, оС	T4, оС	P3, МПа	P4, МПа	M3, Т	M4, Т	Мб, Т	Е2, ГДЖ	ТНС, МИН
23.04.20	68.496	40.124	0.0000	28.372	058.3	045.1	0.700	0.500	67.425	39.736	0.0000	9.0924	0.0000
22.04.20	73.769	43.144	0.0000	30.625	058.5	044.8	0.700	0.500	72.611	42.732	0.0000	9.6504	0.0000
21.04.20	74.509	43.770	0.0000	30.739	058.7	045.2	0.700	0.500	73.332	43.346	0.0000	9.7593	0.0000
20.04.20	72.220	43.922	0.0000	28.298	058.7	045.2	0.700	0.500	71.076	43.496	0.0000	9.1833	0.0000
19.04.20	70.065	44.142	0.0000	25.923	058.9	045.2	0.700	0.500	68.950	43.713	0.0000	8.6780	0.0000
18.04.20	82.595	43.358	0.0000	39.237	057.6	044.6	0.700	0.500	81.334	42.948	0.0000	11.368	0.0000
17.04.20	75.329	43.847	0.0000	31.481	058.4	045.0	0.700	0.500	74.147	43.425	0.0000	9.8968	0.0000
16.04.20	78.112	43.697	0.0000	34.415	058.6	045.2	0.700	0.500	76.881	43.274	0.0000	10.542	0.0000
15.04.20	74.568	44.032	0.0000	30.537	058.3	044.9	0.700	0.500	73.404	43.610	0.0000	9.6366	0.0000
14.04.20	74.386	44.068	0.0000	30.318	058.6	045.2	0.700	0.500	73.212	43.640	0.0000	9.6245	0.0000
13.04.20	74.510	44.177	0.0000	30.333	058.9	045.4	0.700	0.500	73.324	43.744	0.0000	9.7020	0.0000
12.04.20	79.242	44.082	0.0000	35.160	058.3	044.9	0.700	0.500	78.007	43.659	0.0000	10.615	0.0000
11.04.20	77.911	44.220	0.0000	33.691	057.0	044.0	0.700	0.500	76.744	43.813	0.0000	10.217	0.0000
10.04.20	76.079	44.449	0.0000	31.630	056.7	044.2	0.700	0.500	74.951	44.037	0.0000	9.7498	0.0000
09.04.20	76.215	44.423	0.0000	31.792	057.7	044.7	0.700	0.500	75.047	44.002	0.0000	9.8049	0.0000
08.04.20	75.358	44.552	0.0000	30.806	058.4	044.9	0.700	0.500	74.179	44.125	0.0000	9.6785	0.0000
07.04.20	76.091	44.740	0.0000	31.350	058.3	045.1	0.700	0.500	74.901	44.308	0.0000	9.8822	0.0000
06.04.20	76.192	44.809	0.0000	31.383	059.5	045.7	0.700	0.500	74.956	44.365	0.0000	10.150	0.0000
05.04.20	80.305	44.508	0.0000	35.796	057.9	044.8	0.700	0.500	79.066	44.083	0.0000	10.674	0.0000
04.04.20	79.314	44.768	0.0000	34.546	058.8	045.5	0.700	0.500	78.056	44.329	0.0000	10.713	0.0000
03.04.20	76.359	45.037	0.0000	31.322	059.4	045.7	0.700	0.500	75.126	44.591	0.0000	10.098	0.0000
02.04.20	75.437	45.074	0.0000	30.364	059.7	045.8	0.700	0.500	74.207	44.625	0.0000	9.9285	0.0000

Вар 36 ГВС 20.txt

01.04.20	76.283	44.954	0.0000	31.328	059.8	046.1	0.700	0.500	75.033	44.502	0.0000	10.164	0.0000	
31.03.20	79.028	44.715	0.0000	34.313	056.4	044.2	0.700	0.500	77.868	44.299	0.0000	9.9820	0.0000	
30.03.20	78.323	44.813	0.0000	33.511	056.1	043.9	0.700	0.500	77.186	44.401	0.0000	9.8256	0.0000	
29.03.20	78.323	44.997	0.0000	33.326	059.1	045.7	0.700	0.500	77.069	44.550	0.0000	10.461	0.0000	
28.03.20	77.397	45.155	0.0000	32.242	059.2	045.8	0.700	0.500	76.153	44.706	0.0000	10.266	0.0000	
27.03.20	76.548	45.190	0.0000	31.358	059.4	045.8	0.700	0.500	75.308	44.739	0.0000	10.100	0.0000	
26.03.20	75.180	45.061	0.0000	30.119	059.5	045.7	0.700	0.500	73.963	44.615	0.0000	9.8130	0.0000	
25.03.20	75.399	43.764	0.0000	31.635	059.7	047.0	0.700	0.500	74.170	43.307	0.0000	9.9524	0.0000	
24.03.20	75.423	42.785	0.0000	32.638	059.9	047.4	0.700	0.500	74.185	42.330	0.0000	10.151	0.0000	
ИТОГО:	2359.0	1370.4	0.0000	988.59	058.5	045.2	0.700	0.500	2321.9	1357.1	0.0000	309.36	0.0000	

Подпись _____
"71"

ОТЧЕТ
 о суточных параметрах узла теплоснабжения
 Диапазон архива : 24.05.20 - 23.04.20
 Абонент _____ Договор N _____
 Адрес _____
 Теплосчетчик СТУ-1 No. 0 V 2.043
 Схема подключения : 14

Дата/Время	V3, м3	V4, м3	V6, м3	V3-V4	T3, °C	T4, °C	P3, МПа	P4, МПа	M3, Т	M4, Т	M6, Т	E2, ГДЖ	ТНС, МИН
24.05.20	70.425	42.246	0.0000	28.179	059.9	045.1	0.700	0.500	69.268	41.839	0.0000	9.4135	0.0000
23.05.20	71.724	42.227	0.0000	29.497	059.1	044.6	0.700	0.500	70.574	41.828	0.0000	9.6230	0.0000
22.05.20	69.556	42.498	0.0000	27.058	060.0	045.0	0.700	0.500	68.409	42.088	0.0000	9.2168	0.0000
21.05.20	70.155	42.414	0.0000	27.740	060.0	045.4	0.700	0.500	69.000	41.999	0.0000	9.2803	0.0000
20.05.20	68.695	38.826	0.0000	29.869	060.1	047.4	0.700	0.500	67.560	38.413	0.0000	9.3563	0.0000
19.05.20	70.765	44.329	0.0000	26.436	060.2	045.2	0.700	0.500	69.592	43.900	0.0000	9.1934	0.0000
18.05.20	72.143	44.139	0.0000	28.004	059.9	045.5	0.700	0.500	70.959	43.706	0.0000	9.4401	0.0000
17.05.20	75.058	44.026	0.0000	31.032	059.1	045.0	0.700	0.500	73.854	43.602	0.0000	9.9465	0.0000
16.05.20	73.440	44.169	0.0000	29.271	059.7	045.3	0.700	0.500	72.242	43.739	0.0000	9.6953	0.0000
15.05.20	71.167	44.484	0.0000	26.683	060.4	045.7	0.700	0.500	69.980	44.044	0.0000	9.2477	0.0000
14.05.20	72.772	44.402	0.0000	28.371	059.9	045.6	0.700	0.500	71.578	44.964	0.0000	9.5102	0.0000
13.05.20	71.990	44.420	0.0000	27.571	060.0	045.6	0.700	0.500	70.805	43.982	0.0000	9.3393	0.0000
12.05.20	70.123	43.006	0.0000	27.117	059.4	045.2	0.700	0.500	68.989	42.588	0.0000	9.0686	0.0000
11.05.20	74.741	43.188	0.0000	31.553	059.3	045.1	0.700	0.500	73.536	42.771	0.0000	10.065	0.0000
10.05.20	70.117	43.662	0.0000	26.455	060.0	045.4	0.700	0.500	68.962	43.235	0.0000	9.0627	0.0000
09.05.20	69.717	43.983	0.0000	25.733	059.8	045.4	0.700	0.500	68.574	43.553	0.0000	8.8635	0.0000
08.05.20	72.066	43.726	0.0000	28.340	059.8	045.5	0.700	0.500	70.885	43.297	0.0000	9.4776	0.0000
07.05.20	72.307	43.875	0.0000	28.432	059.5	045.1	0.700	0.500	71.134	43.451	0.0000	9.4469	0.0000
06.05.20	70.536	43.839	0.0000	26.697	059.7	045.1	0.700	0.500	69.384	43.415	0.0000	9.1050	0.0000
05.05.20	74.886	43.633	0.0000	31.253	059.0	044.9	0.700	0.500	73.692	43.216	0.0000	9.9395	0.0000
04.05.20	73.425	43.818	0.0000	29.607	059.1	044.7	0.700	0.500	72.250	43.401	0.0000	9.6698	0.0000
03.05.20	74.514	43.593	0.0000	30.921	058.7	044.5	0.700	0.500	73.336	43.183	0.0000	9.8096	0.0000
02.05.20	69.455	43.240	0.0000	26.215	059.5	044.9	0.700	0.500	68.327	42.825	0.0000	8.9253	0.0000
01.05.20	73.852	42.946	0.0000	30.905	058.8	044.9	0.700	0.500	72.682	42.535	0.0000	9.7730	0.0000
30.04.20	73.254	43.190	0.0000	30.064	059.1	045.4	0.700	0.500	72.081	42.767	0.0000	9.6293	0.0000
29.04.20	73.650	43.802	0.0000	29.849	058.7	045.2	0.700	0.500	72.486	43.376	0.0000	9.5100	0.0000
28.04.20	72.969	43.926	0.0000	29.043	059.2	045.8	0.700	0.500	71.797	43.489	0.0000	9.3767	0.0000
27.04.20	73.940	43.819	0.0000	30.121	058.9	045.7	0.700	0.500	72.763	43.384	0.0000	9.5678	0.0000
26.04.20	76.260	43.697	0.0000	32.563	058.0	044.9	0.700	0.500	75.082	43.278	0.0000	9.9394	0.0000
25.04.20	72.126	40.691	0.0000	31.435	056.5	043.6	0.700	0.500	71.065	40.322	0.0000	9.2752	0.0000
24.04.20	72.220	43.922	0.0000	28.298	058.7	045.2	0.700	0.500	71.076	43.496	0.0000	9.1833	0.0000
ИТОГО:	2238.0	1343.7	0.0000	894.30	057.5	043.8	0.677	0.484	2201.9	1330.7	0.0000	292.95	0.0000

Подпись "23"

89,4,3 м³

69,92 Гкал

Отчет Вар 36 отопление май 20.txt

О суточных параметрах узла теплоснабжения
 Диапазон архива : 30.04.20 - 23.04.20

Абонент _____ Договор N _____

Адрес _____

Теплосчетчик СТУ-1 No. 0 V 2.043

Схема подключения : 14

Дата/Время	V1, м3	V2, м3	V5, м3	V1-V2	T1, оС	T2, оС	P1, МПа	P2, МПа	M1, Т	M2, Т	M5, Т	E1, ГДЖ	ТНС, МИН
30.04.20	502.59	490.89	0.0000	11.698	034.7	033.9	0.700	0.500	499.74	488.19	0.0000	4.0458	0.0000
29.04.20	1710.4	1681.7	0.0000	28.696	043.4	041.4	0.700	0.500	1695.2	1667.9	0.0000	14.380	0.0000
28.04.20	1706.6	1678.8	0.0000	27.843	044.2	042.1	0.700	0.500	1690.9	1664.6	0.0000	15.639	0.0000
27.04.20	1711.5	1683.7	0.0000	27.852	042.8	040.9	0.700	0.500	1696.7	1670.2	0.0000	13.962	0.0000
26.04.20	1713.3	1685.1	0.0000	28.160	042.7	040.8	0.700	0.500	1698.6	1671.8	0.0000	14.248	0.0000
25.04.20	1710.9	1682.5	0.0000	28.388	043.3	041.2	0.700	0.500	1695.8	1668.9	0.0000	14.937	0.0000
24.04.20	1705.3	1676.7	0.0000	28.659	045.1	042.8	0.700	0.500	1689.0	1662.1	0.0000	16.767	0.0000
Итого:	010726	010570	0.0000	155.74	025.6	025.1	0.677	0.484	010631	010456	0.0000	94.123	0.0000

22, 63 град

Подпись _____
 "F4"